Ottawa Carleton District School Board - Accessibility Summary (Accessibility Audit - All Zones)

			Exterior									Interior																									Special Areas / Equipment												
Facility Code	Facility Name	Zone	Accessible Sidewalks/Walkways	Accessible Exterior Ramp	Accessible Exterior Stairs/Steps	Accessible Handrails	Accessible Parking	Accessible Loading Zone/Lay-by	Accessible Grounds/Play Areas	Accessible Entrances/Doors	Exterior Door Operators	Interior Door Operators	Magnetic Hold Open Locks	Accessible Corridors	Accessible Lever Hardware	Accessible Elevator	Accessible Stair Lifts	Accessible Interior Ramps	Accessible Stairs	Accessible Handrails	Accessible Drinking Fountains	Accessible Stage	Accessible Change Rooms/Showers	Accessible Main Washrooms	Dedicated Unit Washroom	All-Inclusive single use Washroom	Private, All-Inclusive change rooms / stalls	Accessible Main Office/Reception	Accessible Classrooms	Accessible Library	Accessible Lunch/Staff Room	Accessible Gymnasium	Accessible Labs/Shops	Visual/Strobe Alarms	Accessible Signage	Accessible Classroom Sink/Cabinets	Accessible Auditorium Seating	Accessible Cafeteria Servery	Accessible Library Work Areas	Accessible Lunch/Staff Room Cabinets	Accessible Swimming Pool/Equipment	Time Out Rooms	Fixed Height Adj. Plinths	Emergency Evac. Chairs	Portable Stair Lift	Overhead Lifts (qty)	Comments/Additional Information
071	A Lorne Cassidy ES	West	YES	N/A	N/A	N/A	YES	YES	YES	YES	NO	NO	NO	YES	NO	YES	NO	N/A	NO	NO	YES	NO	NO	YES			N/A	YES	YES	YES	YES	YES	NO		NO	NO	N/A	N/A	YES	NO	N/A	N/A	NO					
201	A Y Jackson SS	West	YES	N/A	N/A	N/A	YES	YES	YES	YES	NO	NO	YES	YES	NO	N/A	N/A	YES	NO	NO	NO	NO	NO	YES		YES		NO	NO	NO	YES	YES	NO		NO	N/A	YES	YES	NO	NO	N/A	N/A	NO					
AAHS	Aboriginal Alternate High School Program	Central	NO	NO	YES	NO	NO	NO	N/A	NO	NO	NO	NO	YES	NO	YES	N/A	NO	YES	NO	NO	N/A	NO	NO			N/A	NO	NO	N/A	NO	YES	N/A	NO	NO	NO	N/A	N/A	N/A	NO	N/A	N/A	NO					Three storey - not accessible.
369	Admin Building - 133 Greenbank	West	YES	YES	N/A	N/A	YES	YES	N/A	YES	YES	N/A	YES	YES	N/A	YES	N/A	NO	NO	NO	NO	N/A	NO	YES			N/A	YES	N/A	N/A	YES	N/A	N/A		NO	N/A	N/A	YES	N/A	N/A	N/A	N/A	NO					
369	Administration - 440 Albert Street	Central	NO	NO	YES	NO	NO	YES	NO	NO	YES	NO	NO	YES	NO	YES	NO	YES	YES	NO	NO	YES	NO	NO	YES	YES		NO	YES	N/A	YES	N/A	NO	NO	NO	NO	NO	NO	N/A	NO	N/A	N/A	YES					Four storey - Elevator and washrooms not accessible. Gymnasium building not accessible.
051	Adrienne Clarkson E.S.	Central	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES	YES		N/A	YES	YES	YES	YES	YES	YES	YES	NO	YES	N/A	YES	YES	YES	N/A	N/A	NO					
227	Adult High School	Central	NO	YES	YES	NO	YES	NO	NO	YES	YES	YES	YES	YES	NO	YES	YES	YES	YES	NO	NO	YES	YES	NO		YES		YES	YES	NO	YES	YES	NO	NO	NO	NO	YES	NO	NO	NO	N/A	N/A	NO					Five stoery - Elevator accessible. Washrooms not accessible. Library/auditorium not accessible.
076	Agincourt Road Public School	Central	NO	NO	NO	NO	NO	NO	NO	YES	NO	NO	NO	YES	NO	YES	NO	N/A	YES	NO	NO	NO	NO	YES			N/A	NO	YES	YES	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Elevator not accessible. Washrooms accessible.
077	Alta Vista Public School	East	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	N/A	YES	NO	NO	NO	NO	NO	YES	YES	N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Split level. No elevator, washrooms not accessible.
078	Arch Street Public School	East	NO	N/A	N/A	N/A	YES	YES	YES	NO	NO	NO	NO	YES	NO	YES	N/A	N/A	YES	NO	NO	NO	NO	NO			N/A	NO	NO	NO	N/A	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Washrooms and elevator not accessible.
143	Avalon P.S.	East	YES	N/A	N/A	NO	YES	YES	NO	YES	YES	YES	YES	YES	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES	NO		N/A	YES	YES	YES	YES	YES	YES	YES	NO	YES	N/A	YES	YES	YES	N/A	N/A	NO					
001	Barrhaven PS	West	YES	NO	NO	NO	YES	NO	NO	YES	NO	NO	NO	YES	NO	N/A	N/A	N/A	NO	NO	NO	NO	NO	NO			N/A	NO	YES	YES	N/A	YES	N/A		NO	NO	N/A	N/A	YES	YES	N/A	N/A	NO					
002	Bayshore PS	West	YES	N/A	N/A	N/A	YES	NO	NO	YES	NO	NO	NO	YES	NO	N/A	N/A	N/A	NO	NO	NO	N/A	N/A	NO			N/A	YES	YES	YES	YES	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
121	Bayview Public School (Formerly R. Byrns Curry P.S.)	Central	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	NO	NO	YES	NO	N/A	N/A	N/A	N/A	N/A	YES	NO	N/A	NO	YES	YES	N/A	NO	YES	YES	N/A	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Washrooms not accessible.
202	Bell HS	West	NO	N/A	N/A	N/A	YES	YES	N/A	NO	YES	NO	YES	YES	NO	N/A	N/A	N/A	NO	NO	NO	NO	NO	NO		YES	YES	NO	NO	NO	YES	YES	NO		NO	NO	N/A	YES	NO	NO	N/A	N/A	NO					
003	Bells Corners ES	West	YES	N/A	NO	NO	YES	YES	YES	YES	NO	NO	YES	YES	NO	YES	N/A	N/A	NO	NO	NO	NO	NO	NO			N/A	NO	YES	YES	NO	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
137	Berrigan E.S.	Central	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES	YES		N/A	YES	YES	YES	YES	YES	YES	YES	NO	YES	N/A	YES	YES	YES	N/A	N/A	NO					
005	Blossom Park Public School	East	YES	YES	NO	NO	NO	NO	YES	NO	NO	NO	YES	YES	NO	N/A	N/A	N/A	N/A	N/A	NO	N/A	NO	NO		YES	N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	YES	NO					One storey - Washrooms not accessible.
006	Briargreen PS	West	YES	N/A	N/A	N/A	YES	YES	YES	YES	NO	NO	NO	YES	NO	N/A	N/A	YES	NO	N/A	NO	NO	N/A	YES		YES	N/A	NO	YES	YES	YES	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
064	Bridlewood Community ES	West	YES	N/A	N/A	N/A	YES	YES	YES	YES	NO	NO	YES	YES	NO	N/A	N/A	N/A	NO	NO	NO	NO	NO	YES			N/A	YES	YES	YES	YES	YES	NO		NO	NO	N/A	N/A	NO	NO	N/A	YES	NO					
080	Broadview Public School	Central	NO	YES	NO	YES	NO	NO	NO	YES	NO	NO	NO	NO	NO	NO	YES	N/A	YES	NO	NO	NO	NO	NO			N/A	NO	NO	YES	NO	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - No elevator. Washrooms not accessible. Original school not accessible.
228	Brookfield High School	Central	NO	YES	YES	NO	NO	NO	YES	NO	NO	NO	NO	YES	NO	NO	NO	NO	YES	NO	NO	YES	NO	NO				NO	YES	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	N/A	N/A	NO					Two storey - not accessible. No elevator.
203	Cairine Wilson Secondary School	East	YES	N/A	N/A	N/A	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	NO	N/A	YES	NO	YES	NO	YES	YES		YES		YES	YES	YES	YES	YES	YES	YES	NO	NO	YES	NO	NO	NO	N/A	N/A	NO		YES			Two storey - Elevator not accessible. HC washroom/shower accessible.
081	Cambridge Street Community Public School	Central	YES	NO	NO	NO	YES	NO	YES	NO	NO	NO	YES	YES	NO	NO	NO	N/A	YES	NO	YES	NO	N/A	NO		YES	N/A	NO	YES	YES	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Elevator and washrooms not accessible.
229	Canterbury High School	East	YES	YES	YES	NO	YES	YES	YES	NO	YES	YES	YES	YES	NO	YES	N/A	N/A	YES	NO	YES	YES	NO	YES				YES	YES	YES	YES	YES	YES	NO	NO	NO	YES	NO	NO	NO	N/A	N/A	NO				1	Three storey - HC washroom accessible. Elevator accessible
082	Carleton Heights P.S.	Central	NO	N/A	N/A	N/A	NO	YES	YES	YES	NO	NO	YES	YES	NO	NO	NO	N/A	YES	NO	NO	NO	YES	NO			N/A	NO	NO	YES	NO	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - No elevator. HC accessible washroom/shower on main floor.
008	Carson Grove Elementary School	East	NO	N/A	N/A	NO	YES	YES	NO	NO	NO	NO	NO	YES	NO	NO	NO	NO	NO	NO	NO	N/A	NO	NO			N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Open plan school - Lower level not accessible. Washrooms not accessible.
066	Castelfrank ES	West	YES	N/A	N/A	N/A	YES	NO	YES	YES	YES	NO	YES	YES	NO	N/A	N/A	N/A	NO	NO	YES	N/A	N/A	YES	YES		N/A	YES	YES	YES	YES	YES	N/A		NO	YES	N/A	N/A	NO	NO	N/A	N/A	NO					
063	Castor Valley Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	NO	YES	YES	NO	N/A	N/A	N/A	N/A	N/A	YES	N/A	NO	NO			N/A	YES	YES	N/A	YES	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Washrooms not accessible.
073	Cedarview MS	West	YES	N/A	NO	NO	YES	YES	YES	YES	YES	YES	NO	YES	YES	YES	N/A	N/A	YES	YES	YES	YES	YES	YES		YES		YES	YES	YES	YES	YES	NO		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
083	Centennial Public School	Central	YES	YES	YES	NO	YES	YES	YES	NO	YES	YES	YES	YES	NO	YES	NO	YES	YES	NO	YES	YES	YES	YES	YES		N/A	NO	YES	NO	NO	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	YES	N/A	YES				6	Two storey - Elevator and washrooms/showers accessible. Accessible pool and exterior ramps.
009	Century Public School	Central	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	YES	NO	NO	NO	N/A	YES	NO	NO	NO	NO	NO		YES	N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - No elevator. Washrooms not accessible. Exterior ramps not accessible.
147	Chapman Mills Public School	Central	YES		YES		YES	YES	YES	YES	YES			YES	YES	YES		N/A	YES	YES	YES	YES	N/A	YES	YES		N/A	YES	YES	YES	YES	YES	N/A		YES		N/A	N/A	YES		N/A	N/A	NO					New Facility. To be reviewed / verified
084	Charles H. Hulse P.S.	East	YES	N/A	N/A	N/A	NO	YES	YES	NO	YES	YES	YES	YES	YES	YES	N/A	N/A	YES	NO	NO	NO	YES	NO			N/A	NO	NO	NO	N/A	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Washrooms and elevator not accessible.
086	Churchill Alternative School	Central	YES	N/A	N/A	N/A	YES	NO	YES	YES	YES	NO	NO	YES	NO	YES	NO	N/A	YES	YES	YES	NO	NO	YES			N/A	YES	YES	YES	YES	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - Elevator and washrooms accessible. HC parking a long distance from entrance.
087	Clifford Bowey Public School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	YES	YES	YES	YES	NO	YES	YES	NO	NO	NO	NO	YES	YES	YES	YES		N/A	NO	YES	N/A	YES	YES	N/A	NO	YES	NO	N/A	N/A	NO	NO	YES	YES	YES				7	Two storey - Washrooms accessible, elevator not accessible.
204	Colonel By Secondary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	YES	YES	YES	YES	NO	YES	NO	NO	YES	NO	NO	NO	NO	NO	YES	YES		YES	YES	YES	YES	YES	NO	NO	NO	NO	NO	NO	NO	NO	N/A	N/A	YES	YES				Two storey - Split level steps. Elevator not accessible. Washrooms not accessible.
205	Confederation HS	West	YES	YES	NO	NO	YES	YES	YES	YES	NO	NO	NO	YES	NO	YES	N/A	N/A	NO	NO	YES	NO	NO	YES		YES		YES	YES	NO	N/A	YES	N/A		NO	YES	N/A	N/A	NO	N/A	N/A	N/A	NO					
088	Connaught Public School	Central	YES	YES	YES	NO	YES	NO	YES	YES	YES	NO	YES	YES	YES	NO	N/A	YES	YES	YES	YES	YES	NO	NO			N/A	YES	YES	YES	YES	YES	YES	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - Elevator accessible. Washrooms not accessible. Exterior ramp accessible.
011	Convent Glen Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	NO	NO	YES	NO	N/A	N/A	NO	YES	NO	NO	NO	NO	NO			N/A	YES	YES	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Partially open plan. Washrooms not accessible.
200	Crystal Bay Centre	West	YES	YES	YES	NO	YES	YES	NO	YES	NO	NO	NO	YES	YES	N/A	N/A	N/A	N/A	N/A	NO	N/A	NO	YES			N/A	YES	YES	YES	YES	YES	N/A		NO	NO	N/A	YES	NO	NO	N/A	YES	NO				5	
012	D A Moodie IS	West	YES	N/A	YES	NO	YES	YES	YES	YES	NO	NO	NO	YES	YES	N/A	N/A	N/A	NO	NO	NO	NO	NO	YES	YES	YES	N/A	YES	YES	YES	YES	YES	NO		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
090	D. Roy Kennedy Public School	Central	YES	YES	YES	NO	NO	YES	YES	NO	NO	NO	NO	YES	NO	YES	NO	N/A	YES	NO	YES	NO	NO	YES	YES		N/A	NO	NO	YES	NO	NO	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey -Elevator not accessible. Washrooms accessible.
091	Devonshire Community Public School	Central	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	YES	NO	YES	NO	YES	NO	NO	NO	NO	N/A	YES	YES	YES	N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - No accessibility.
092	Dunlop Public School	East	NO	N/A	N/A	N/A	NO	YES	YES	NO	YES	NO	NO	NO	YES	N/A	N/A	N/A	N/A	N/A	NO	NO	NO	NO		YES	N/A	NO	YES	YES	N/A	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Open plan. Washrooms not accessible.
058	Dunning-Foubert Elementary School	East	YES	N/A	N/A	N/A	NO	YES	YES	NO	YES	NO	NO	YES	NO	N/A	N/A	NO	N/A	NO	YES	N/A	NO	YES	YES		N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Washrooms accessible. Ramp in library not accessible.

Ottawa Carleton District School Board - Accessibility Summary (Accessibility Audit - All Zones)

			Exterior									Interior																									Special Areas / Equipment											
Facility Code	Facility Name	Zone	Accessible Sidewalks/Walkways	Accessible Exterior Ramp	Accessible Exterior Stairs/Steps	Accessible Handrails	Accessible Parking	Accessible Loading Zone/Lay-by	Accessible Grounds/Play Areas	Accessible Entrances/Doors	Exterior Door Operators	Interior Door Operators	Magnetic Hold Open Locks	Accessible Corridors	Accessible Lever Hardware	Accessible Elevator	Accessible Stair Lifts	Accessible Interior Ramps	Accessible Stairs	Accessible Handrails	Accessible Drinking Fountains	Accessible Stage	Accessible Change Rooms/Showers	Accessible Main Washrooms	Dedicated Unit Washroom	All-Inclusive single use Washroom	Private, All-Inclusive change rooms / stalls	Accessible Main Office/Reception	Accessible Classrooms	Accessible Library	Accessible Lunch/Staff Room	Accessible Gymnasium	Accessible Labs/Shops	Visual/Strobe Alarms	Accessible Signage	Accessible Classroom Sink/Cabinets	Accessible Auditorium Seating	Accessible Cafeteria Servery	Accessible Library Work Areas	Accessible Lunch/Staff Room Cabinets	Accessible Swimming Pool/Equipment	Time Out Rooms	Fixed Height Adj. Plinths	Emergency Evac. Chairs	Portable Stair Lift	Overhead Lifts (qty)	Comments/Additional Information
206	Earl of March SS	West	YES	N/A	N/A	N/A	YES	NO	YES	YES	YES	NO	YES	YES	NO	YES	N/A	YES	YES	NO	YES	NO	YES	YES	YES			NO	YES	YES	YES	YES	NO		NO	NO	NO	N/A	NO	NO	N/A	N/A	NO					
093	Elgin Street Public School	Central	YES	YES	YES	NO	NO	NO	NO	NO	YES	NO	NO	YES	NO	NO	NO	N/A	YES	NO	NO	NO	N/A	NO		YES	N/A	NO	YES	NO	YES	N/A	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - No accesssibility.
070	Elizabeth Park Public School	Central	YES	NO	NO	NO	YES	NO	YES	NO	YES	NO	NO	NO	NO	NO	YES	N/A	YES	NO	NO	NO	NO	NO			N/A	NO	YES	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Split level. No elevator. Washrooms not accessible. Stair lift in corridor.
216	Elizabeth Wyn Wood Secondary Alternate Program	Central	YES	N/A	N/A	N/A	YES	NO	YES	NO	YES	YES	YES	YES	NO	N/A	NO	N/A	N/A	N/A	YES	NO	NO	YES		YES		YES	NO	N/A	NO	YES	NO	NO	NO	NO	N/A	NO	NO	NO	N/A	N/A	NO					One storey - HC washroom accessible.
094	Elmdale Public School	Central	YES	YES	NO	NO	NO	NO	NO	NO	YES	NO	NO	YES	NO	NO	NO	N/A	YES	NO	NO	NO	NO	NO			N/A	NO	NO	YES	NO	NO	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - No accessibility.
013	Emily Carr M.S.	East	YES	NO	YES	NO	NO	YES	NO	NO	YES	NO	NO	YES	NO	YES	N/A	N/A	YES	NO	NO	YES	NO	NO		YES	N/A	NO	YES	YES	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Multi-level open plan - elevator and washrooms not accessible.
065	Fallingbrook Community Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	YES	NO	NO	YES	NO	N/A	N/A	YES	YES	NO	YES	NO	N/A	NO	YES		N/A	YES	YES	YES	YES	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Washrooms not accessible. Ramp in library requires access. handrails.
142	Farley Mowat P.S	Central	YES	YES	YES	YES	YES	YES	NO	YES	YES	NO	YES	YES	YES	YES	YES	YES	NO	YES	YES	NO	YES	YES	YES		N/A	YES	YES	YES	YES	YES	YES	YES	NO	YES	N/A	N/A	YES	YES	N/A	N/A	NO					
095	Featherston Drive Public School	East	YES	N/A	N/A	N/A	NO	YES	YES	NO	YES	NO	YES	NO	NO	NO	N/A	N/A	YES	NO	YES	NO	N/A	YES	YES		N/A	NO	NO	YES	YES	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	YES	NO					Two storey - Split level. No elevator, washrooms accessible.
096	Fielding Drive Public School	Central	YES	N/A	N/A	N/A	YES	NO	YES	NO	YES	NO	YES	YES	NO	N/A	NO	YES	N/A	NO	NO	NO	YES	NO			N/A	NO	NO	NO	YES	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Washrooms not accessible. Girl's change rooms/showers accessible.
097	First Avenue Public School	Central	YES	YES	YES	NO	YES	NO	YES	YES	NO	NO	YES	YES	NO	YES	YES	YES	YES	NO	YES	NO	NO	NO			N/A	NO	YES	YES	YES	YES	N/A	YES	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey plus basement - Elevator accessible. Washrooms not accessible. Interior ramp accessible.
098	Fisher Park Public School/Summit AS	Central	YES	YES	YES	YES	YES	NO	NO	NO	NO	NO	NO	YES	NO	YES	NO	YES	YES	NO	YES	NO	NO	YES		YES		NO	NO	NO	YES	YES	NO	NO	NO	NO	YES	NO	NO	NO	N/A	N/A	NO					Four storey - Elevator and washrooms accessible. Accessible interior ramps.
067	Forest Valley Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	YES	NO	NO	YES	YES	N/A	N/A	N/A	N/A	N/A	YES	N/A	YES	YES			N/A	YES	YES	YES	N/A	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Accessible washrooms.
221	Frederick Banting Secondary Alternative Prgm (Formerly	West	YES	YES	YES	YES	YES	YES		YES	YES	YES		YES					YES		YES					YES	N/A										N/A				N/A	N/A	NO		YES			
099	General Vanier Public School	Central	YES	N/A	N/A	N/A	NO	NO	YES	NO	NO	NO	NO	YES	NO	NO	NO	N/A	YES	NO	NO	NO	N/A	NO			N/A	NO	NO	YES	NO	YES	N/A	NO	NO	NO	N/A	NO	NO	NO	N/A	N/A	NO					Two storey - No elevator. Washrooms not accessible.
102	Glashan Public School	Central	YES	YES	YES	NO	YES	NO	YES	NO	YES	YES	NO	YES	NO	YES	NO	N/A	YES	NO	YES	NO	NO	NO		YES	N/A	NO	YES	YES	YES	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - Elevator and washrooms not accessible. Exterior entrance ramp accessible.
230	Glebe Collegiate Institute	Central	NO	NO	YES	YES	NO	NO	NO	NO	YES	YES	YES	NO	NO	YES	NO	NO	YES	NO	YES	YES	NO	NO		YES		NO	NO	YES	YES	YES	NO	NO	NO	NO	YES	NO	NO	NO	NO	N/A	NO					Four storey - Historic building. Elevator accessible. Washrooms/pool not accessible.
018	Glen Cairn PS	West	YES	NO	NO	NO	YES	YES	NO	NO	NO	NO	NO	YES	NO	N/A	N/A	N/A	N/A	N/A	YES	N/A	NO	YES			N/A	YES	YES	YES	YES	YES	YES		NO	YES	N/A	N/A	NO	NO	N/A	N/A	NO					
019	Glen Ogilvie Public School	East	YES	N/A	N/A	N/A	NO	YES	NO	NO	YES	NO	NO	NO	NO	NO	NO	N/A	YES	NO	NO	NO	NO	NO			N/A	NO	YES	YES	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey school - Lift in library not accessible. Washrooms not accessible.
208	Gloucester High School	East	YES	N/A	N/A	N/A	YES	NO	YES	NO	YES	YES	YES	YES	NO	YES	NO	N/A	YES	NO	NO	YES	NO	YES				YES	NO	YES	YES	YES	NO	NO	NO	NO	YES	NO	NO	NO	N/A	N/A	NO					Two storey -Elevator not accessible. HC washrooms accessible.
020	Goulbourn MS	West	NO	NO	YES	NO	YES	YES	NO	YES	NO	NO	YES	YES	NO	N/A	N/A	N/A	N/A	N/A	NO	N/A	NO	YES	YES	YES	N/A	YES	YES	YES	NO	YES	NO		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
085	Grant Alternative School (Formerly Christie PS)	West	YES	N/A	N/A	N/A	YES	NO	YES	YES	NO	NO	N/A	YES	NO	N/A	N/A	N/A	NO	N/A	NO	N/A	N/A	YES			N/A	NO	YES	YES	NO	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					New Grant Alternative School (formerly Christie P.S.)
022	Greely Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	YES	NO	NO	YES	YES	N/A	N/A	N/A	N/A	N/A	YES	NO	N/A	YES			N/A	YES	YES	YES	YES	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Accessible washrooms.
023/029	Greenbank MS / Knoxdale PS	West	YES	N/A	N/A	N/A	NO	YES	YES	YES	YES	YES	YES	YES	NO	YES	N/A	N/A	YES	NO	YES	NO	NO	YES	YES		N/A	NO	YES	NO	YES	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
153	Half Moon Bay PS	West	YES	N/A	N/A	N/A	YES	YES	YES	YES	YES			YES	YES	YES	N/A	N/A	YES	YES	YES	YES	N/A	YES	YES	YES	N/A	YES	YES	YES	YES	YES	N/A		YES		N/A	N/A	YES		N/A	N/A	NO					
104	Hawthorne P.S.	East	YES	N/A	N/A	N/A	YES	NO	YES	NO	NO	NO	NO	YES	NO	NO	NO	NO	YES	NO	NO	NO	NO	NO		YES	N/A	NO	YES	YES	YES	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - No elevator. Washrooms not accessible.
062	Henry Larson Elementary School	East	YES	N/A	N/A	N/A	NO	YES	YES	NO	NO	NO	NO	YES	NO	N/A	N/A	N/A	N/A	N/A	NO	N/A	NO	NO	YES	YES	N/A	YES	YES	YES	YES	YES	YES	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					One storey - Washrooms not accessible.
025	Henry Munro Middle School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	NO	NO	YES	NO	YES	N/A	N/A	YES	NO	YES	NO	NO	N0			N/A	NO	YES	YES	NO	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					TWo storey school - Elevator and washrooms not accessible.
037	Heritage P.S.	East	YES	NO	NO	NO	YES	YES	NO	YES	YES	YES	NO	YES	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES	YES		N/A	YES	YES	YES	YES	YES	NO	YES	NO	YES	N/A	YES	YES	YES	N/A	N/A	NO					
231	Hillcrest High School	East	YES	NO	YES	NO	NO	YES	NO	NO	NO	NO	NO	YES	NO	NO	NO	NO	YES	NO	NO	YES	NO	NO	YES			YES	YES	YES	NO	YES	NO	NO	NO	NO	YES	NO	NO	NO	N/A	N/A	NO					Three storey - No elevator. Washrooms not accessible. Steps in lobby and lunch room.
105	Hilson Avenue Public School	Central	YES	N/A	N/A	N/A	YES	YES	YES	YES	YES	NO	NO	YES	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES			N/A	YES	YES	YES	YES	YES	YES	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Accessible.
106	Hopewell Avenue Public School	Central	YES	YES	YES	NO	YES	NO	YES	YES	YES	YES	NO	NO	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES			N/A	YES	YES	YES	YES	YES	YES	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - Accessible. Parking garage at basement level.
026	Huntley Centennial PS	West	YES	N/A	YES	NO	YES	NO	YES	YES	NO	NO	NO	YES	NO	N/A	N/A	N/A	YES	NO	YES	NO	NO	YES		YES	N/A	NO	YES	YES	YES	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
107	J. H. Putman Public School	Central	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	YES	NO	YES	NO	YES	NO	N/A	YES	NO	YES	NO	N/A	YES		YES	N/A	NO	NO	NO	YES	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Two storey - Elevator not accessible. Washrooms accessible.
136	Jack Donohue P.S.	West	YES	YES	YES	YES	YES	YES	NO	YES	YES	NO	YES	YES	YES	N/A	N/A	YES	NO	YES	YES	NO	YES	YES	YES	YES	N/A	YES	YES	YES	YES	YES	YES	YES	NO	YES	N/A	N/A	YES	YES	N/A	N/A	NO					
061	Jockvale ES	West	YES	N/A	N/A	N/A	YES	YES	NO	YES	YES	NO	YES	YES	YES	N/A	N/A	N/A	N/A	N/A	YES	N/A	YES	YES			N/A	NO	YES	YES	NO	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
238	John McCrae SS	West	YES	N/A	YES	NO	YES	YES	YES	YES	YES	YES	NO	YES	YES	YES	N/A	YES	YES	NO	YES	NO	YES	YES				YES	YES	YES	YES	YES	NO		NO	YES	N/A	N/A	NO	NO	N/A	N/A	NO					
027	John Young ES	West	YES	N/A	N/A	N/A	YES	NO	YES	YES	YES	YES	YES	YES	NO	N/A	N/A	N/A	N/A	N/A	YES	NO	NO	YES	YES		N/A	YES	YES	YES	YES	YES	N/A		NO	YES	N/A	N/A	NO	NO	N/A	YES	NO					
152	Kanata Highlands PS	West	YES	N/A	N/A	N/A	YES	YES	YES	YES	YES			YES	YES	YES		N/A	YES	YES	YES	YES	N/A	YES	YES	YES	N/A	YES	YES	YES	YES	YES	N/A		YES		N/A	N/A	YES		N/A	N/A	NO					
47	Kars on the Rideau PS	Central					YES			YES									YES		YES		N/A	YES	YES		N/A	YES	YES								N/A				N/A	N/A	NO					
057	Katimavik ES	West	YES	N/A	N/A	N/A	YES	NO	YES	YES	NO	NO	YES	YES	NO	N/A	N/A	YES	N/A	N/A	YES	NO	NO	NO			N/A	YES	YES	YES	YES	YES	N/A		NO	YES	N/A	N/A	NO	NO	N/A	N/A	NO					
135	Lady Evelyn Alternative School	Central	YES	N/A	N/A	N/A	YES	NO	YES	YES	YES	NO	YES	YES	YES	YES	NO	YES	YES	YES	YES	YES	YES	YES			N/A	YES	YES	YES	YES	YES	YES	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Three storey - Accessible. Parking garage at basement level.
030	Lakeview PS	West	YES	N/A	NO	NO	YES	YES	YES	YES	YES	YES	YES	YES	YES	N/A	N/A	N/A	N/A	N/A	NO	N/A	NO	YES	YES		N/A	YES	YES	NO	YES	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
032	Le Phare ES	East	YES	N/A	N/A	N/A	NO	YES	YES	NO	NO	YES	YES	NO	NO	NO	NO	N/A	YES	NO	NO	N/A	N/A	NO			N/A	NO	NO	NO	NO	NO	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					Multi-level open plan - Not accessible.
033	Leslie Park PS	West	YES	N/A	YES	NO	YES	YES	NO	YES	NO	NO	YES	YES	NO	N/A	N/A	N/A	N/A	N/A	NO	NO	N/A	NO			N/A	NO	YES	NO	NO	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO					
226	Lisgar Collegiate Institute	Central	YES	N/A	NO	NO	YES	NO	NO	YES	YES	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	YES	YES		NO	NO	NO	NO	NO	NO	NO	NO	NO	YES	NO	NO	NO	N/A	N/A	NO		YES			Four storey - Historic building w/ Temporary Access. Gymnasium building not accessible.

Ottawa Carleton District School Board - Accessibility Summary (Accessibility Audit - All Zones)

| | | | Exterior | | | | | | | | | Interior | | | | | | | | |

Ottawa Carleton District School Board - Accessibility Summary (Accessibility Audit - All Zones)

			Exterior									Interior																										Special Areas / Equipment											
Facility Code	Facility Name	Zone	Accessible Sidewalks/Walkways	Accessible Exterior Ramp	Accessible Exterior Stairs/Steps	Accessible Handrails	Accessible Parking	Accessible Loading Zone/Lay-by	Accessible Grounds/Play Areas	Accessible Entrances/Doors	Exterior Door Operators	Interior Door Operators	Magnetic Hold Open Locks	Acessible Corridors	Accessible Lever Hardware	Accessible Elevator	Acessible Stair Lifts	Accessible Interior Ramps	Accessible Stairs	Accessible Handrails	Accessible Drinking Fountains	Accessible Stage	Accessible Change Rooms/Showers	Accessible Main Washrooms	Dedicated Unit Washroom	All-Inclusive single use Washroom	Private, All-Inclusive change rooms / stalls	Accessible Main Office/Reception	Accessible Classrooms	Accessible Library	Accessible Lunch/Staff Room	Accessible Gymnasium	Accessible Labs/Shops	Visual/Strobe Alarms	Accessible Signage	Accessible Classroom Sink/Cabinets	Accessible Auditorium Seating	Accessible Cafeteria Servery	Accessible Library Work Areas	Accessible Lunch/Staff Room Cabinets	Accessible Swimming Pool/Equipment	Time Out Rooms	Fixed Height Adj. Plinths	Emergency Evac. Chairs	Portable Stair Lift	Overhead Lifts (qty)	Comments/Additional Information
370	Stittsville Depot	West		N/A	N/A	N/A	YES	YES	N/A	NO	NO	NO	NO	NO		NO	NO	YES			YES	N/A	N/A	NO	YES		N/A	NO	N/A	N/A	YES	N/A	N/A		NO		N/A	N/A	N/A		N/A	N/A	NO	NO				Not Audited
140	Stittsville P.S. (NEW) (111 Hartsmere Dr.)	West	YES	NO	NO	NO	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	NO	N/A	YES	YES	YES	NO	YES	YES	YES		N/A	YES	YES	YES	YES	YES	YES	YES	YES	YES	N/A	YES	YES	YES	N/A	YES	NO				
074	Stonecrest ES	West	YES	YES	YES	NO	YES	YES	YES	YES	YES	YES	YES	YES	YES	N/A	N/A	N/A	N/A	N/A	YES	NO	YES	YES			N/A	YES	YES	YES	YES	YES	YES		NO	YES	N/A	N/A	NO	NO	N/A	N/A	NO				
SFS	Storefront School	East	YES	N/A	N/A	N/A	YES	N/A	N/A	YES	YES	NO	NO	YES	NO	YES	N/A	N/A	YES	YES	N/A	N/A	N/A	YES		N/A	N/A	N/A	YES	N/A	N/A	N/A	N/A	N/A	N/A	NO	N/A	N/A	N/A	NO	N/A	N/A	NO				Classroom in basement of office building.
151	Summerside PS	East	YES	N/A	N/A	N/A	YES	YES	YES	YES	YES			YES	YES	YES		N/A	YES	YES	YES	YES	N/A	YES	YES	YES	N/A	YES	YES	YES	YES	YES	N/A		YES		N/A	N/A	YES		N/A	N/A	NO				
024	Terry Fox Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	YES	NO	YES	NO	N/A	N/A	N/A	N/A	N/A	YES	N/A	NO	YES		YES	N/A	YES	NO	NO	NO	YES	NO	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				One storey - Accessible HC washroom.
072	Trillium Elementary School	East	YES	N/A	N/A	N/A	YES	YES	YES	NO	YES	NO	NO	YES	YES	YES	N/A	N/A	YES	YES	YES	N/A	YES	YES	YES		N/A	YES	YES	YES	YES	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO	YES			Two storey - Elevator not accessible. Washrooms accessible.
129	Vincent Massey Public School	East	NO	N/A	N/A	N/A	YES	NO	YES	NO	YES	NO	YES	YES	NO	NO	NO	N/A	YES	NO	YES	NO	YES	YES	YES		N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				Two storey - Elevator not accessible. HC washroom accessible.
130	Viscount Alexander Public school	Central	NO	YES	NO	NO	NO	YES	YES	NO	NO	NO	NO	NO	NO	N/A	NO	YES	NO	NO	NO	NO	N/A	NO			N/A	NO	YES	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				One stoery -Split level. Steps in corridor. Not accessible. Washrooms not accessible.
131	W. E. Gowling P.S.	Central	YES	N/A	N/A	N/A	NO	NO	NO	NO	NO	NO	NO	YES	NO	NO	NO	N/A	YES	NO	NO	NO	N/A	NO			N/A	NO	NO	YES	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				Two storey - No elevator. Washrooms not accessible.
056	W. E. Johnston PS	West	YES	N/A	YES	NO	YES	YES	YES	YES	YES	NO	YES	YES	NO	YES	N/A	N/A	YES	NO	YES	NO	YES	YES		YES	N/A	YES	NO	NO	NO	YES	N/A		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				
068	W O Mitchell ES	West	YES	N/A	N/A	N/A	YES	YES	NO	YES	NO	NO	N/A	YES	NO	YES	N/A	YES	NO	NO	YES	N/A	YES	YES	YES	YES	N/A	YES	NO	YES	NO	YES	NO		NO	N/A	N/A	YES	NO	NO	N/A	N/A	NO				
219	West Carleton SS	West	YES	N/A	YES	NO	YES	NO	YES	YES	YES	YES	YES	YES	YES	YES	N/A	N/A	YES	NO	YES	N/A	YES	YES				YES	YES	YES	YES	YES	NO		NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				
150	Westwind P.S.	West	YES		YES		YES	YES	YES	YES	YES			YES	YES	YES		N/A	YES	YES	YES	YES	N/A	YES	YES		N/A	YES	YES	YES	YES	YES	N/A		YES		N/A	N/A	YES		N/A	N/A	NO				New Facility. To be reviewed / verified
133	Woodroffe Avenue Public School	Central	YES	N/A	N/A	N/A	YES	YES	YES	NO	NO	NO	YES	NO	NO	NO	NO	N/A	YES	NO	NO	NO	N/A	NO	YES		N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				Two storey - Split level. Steps in corridor. No elevator. Washrooms not accessible.
237	Woodroffe HS	West	YES	YES	YES	NO	YES	YES	YES	YES	YES	NO	YES	YES	NO	YES	N/A	YES	YES	NO	NO	YES	NO	YES		YES		NO	NO	YES	YES	YES	NO		NO	N/A	YES	YES	NO	NO	N/A	N/A	NO				
134	York Street Public School	Central	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	YES	NO	NO	YES	N/A	YES	NO	NO	NO	N/A	NO			N/A	NO	NO	NO	NO	YES	N/A	NO	NO	NO	N/A	N/A	NO	NO	N/A	N/A	NO				Two storey plus basement - Not accessible.