

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
A.Y. Jackson	Filling Station	201-FS4-B	0.006	0.003	daily
Bayshore Public School	121-kindergarten	002-8-1	<0.001	0.001	daily
Bell High School	190-staffroom	202-staff-1	<0.001	<0.001	daily
Bells Corners PS	113-kindergarten	003-113-1	0.003	<0.001	daily
Bill Mason	Kitchen	BillMason -1	0.001	0.001	weekly
Bridlewood	112-kindergarten	064-112-4	0.004	0.001	daily
Castlefrank	110-kindergarten	066-110-1	<0.001	<0.001	daily
Crystal Bay	107	200-3-1	0.002	0.001	daily
Earl of March H.S.	252A - kitchenette (251A)	206-252A-1	0.004	0.004	daily
Glen Cairn	Filling Station	018-FS1-B	0.001	<0.001	daily
Frederick Banting	Filling Station	221-FS1-B	0.001	<0.001	daily
Huntley Centennial	145-kindergarten	026-36-1	0.001	0.002	weekly
Jack Donohue	115-kindergarten	136-100-2	<0.001	<0.001	no flushing
John Young	148-kindergarten	027-148-2	<0.001	<0.001	daily
Kanata Highlands	123-kindergarten	152-123-1	<0.001	<0.001	weekly
Katimavik	Filling Station	057-FS2-B	0.001	<0.001	daily
Lakeview	125-kindergarten	030-125-1	<0.001	<0.001	no flushing
Roch Carrier	133-serverry	139-119-2	<0.001	<0.001	no flushing
Roland Michener	144-kindergarten	050-136-3	0.002	0.001	daily
South March	117-kindergarten	146-117-1	<0.001	<0.001	weekly
Stephen Leacock	Filling Station	053-FS1-B	<0.001	<0.001	no flushing
Stonecrest	123-kindergarten	074-102-2	0.002	<0.001	weekly
W.E. Johnston	122-kindergarten	056-122-1	<0.001	<0.001	daily
W.O. Mitchell	102-kindergarten	068-102-1	0.001	<0.001	no flushing
West Carleton SS	Filling Station	219-FS3-B	0.001	0.001	daily
Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)					
Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.					
Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.					