

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
A. Lorne Cassidy	Filling Station	71-FS1-B	<0.001	<0.001	daily
Adrienne Clarkson	115-kindergarten	051-113-3	0.001	<0.001	no flushing
Barrhaven	110-kindergarten	001-8-1	0.004	0.002	daily
Berrigan	Filling Station	137-FS2-B	<0.001	<0.001	weekly
Castor Valley	142-kindergarten	063-3-2	0.001	<0.001	weekly
Cedarview	317-family studies (rm142)	073-317-3	0.003	0.001	daily
Chapman Mills	125A - servery	147-125A-1	<0.001	<0.001	no flushing
D.A. Moodie	Filling Station	012-FS1-B	0.005	0.002	daily
Farley Mowat	125-kindergarten	142-125-1	0.001	<0.001	no flushing
Goulbourn	Health Bar room 122	020-122-1	0.005	0.002	daily
Greely	Filling Station	022-FS3-B	<0.001	<0.001	daily
Half Moon Bay	Filling Station	153-FS2-B	<0.001	<0.001	no flushing
Jockvale	113-kindergarten	061-7-1	0.010	0.006	daily
John McCrae S.S.	Filling Station	238-FS7-B	<0.001	<0.001	weekly
Kars on the Rideau	Filling Station	047-FS4-B	<0.001	0.001	weekly
Longfields-Davidson Heights S.S.	Filling Station	239-FS6-B	<0.001	<0.001	weekly
Manotick	100-kindergarten	035-1-1	0.001	<0.001	weekly
Mary Honeywell	135	069-135-1	0.001	0.001	weekly
Metcalf	122-kindergarten	039-114-1	0.001	<0.001	weekly
	147a - New staffroom	039-147a-1	0.002	<0.001	no flushing
		039-147a-2	0.003	<0.001	no flushing
North Gower	115-kindergarten	041-113A-2	0.001	<0.001	weekly
Osgoode Township H.S.	Filling Station	212-FS5-B	0.006	0.002	daily
	144 DSP	212-144-1	0.001	<0.001	no flushing
Osgoode P.S.	110 kitchen	042-110-1	0.006	0.001	daily
Richmond	117-kindergarten	046-117-2	0.002	0.001	daily
Shingwàkons P.S.	Filling Station	160-FS1-A	<0.001	<0.001	no flushing
		160-FS1-B	<0.001	<0.001	no flushing
	Filling Station	160-FS2-A	<0.001	<0.001	no flushing
		160-FS2-B	0.001	<0.001	no flushing
	Filling Station	160-FS3-A	<0.001	<0.001	no flushing
		160-FS3-B	<0.001	<0.001	no flushing
	Filling Station	160-FS4-A	<0.001	<0.001	weekly
		160-FS4-B	<0.001	<0.001	weekly
	Filling Station	160-FS5-A	<0.001	<0.001	no flushing
		160-FS5-B	0.001	<0.001	no flushing
	Filling Station	160-FS6-A	0.001	0.002	no flushing
		160-FS6-B	0.001	0.001	no flushing
	Drinking Fountain	160-F1	<0.001	<0.001	weekly
	Drinking Fountain	160-F2	<0.001	<0.001	no flushing
	135 - servery	160-135-1	<0.001	<0.001	no flushing
		160-135-2	0.001	<0.001	no flushing
	136 - kindergarten	160-136-1	<0.001	<0.001	no flushing
		160-136-2	0.001	<0.001	no flushing
	137 - kindergarten	160-137-1	<0.001	0.001	weekly
		160-137-2	<0.001	0.001	weekly
	138 - kindergarten	160-138-1	<0.001	<0.001	weekly
		160-138-2	<0.001	<0.001	weekly
	139 - kindergarten	160-139-1	<0.001	<0.001	no flushing
		160-139-2	<0.001	<0.001	no flushing
	101 - staffroom	160-101-1	0.009	<0.001	daily
	116 - kindergarten	160-116-1	0.001	<0.001	weekly
		160-116-2	0.002	0.001	weekly
	117 - kindergarten	160-117-1	0.001	<0.001	weekly
		160-117-2	<0.001	<0.001	weekly
	118 - kindergarten	160-118-1	<0.001	<0.001	daily
		160-118-2	<0.001	<0.001	daily
	119 - kindergarten	160-119-1	<0.001	<0.001	daily
160-119-2		<0.001	<0.001	daily	
124 - daycare kitchen	160-124-1	0.009	<0.001	no flushing	
	160-124-2	<0.001	<0.001	no flushing	
125 - preschool	160-125-1	<0.001	<0.001	no flushing	
	160-125-2	0.001	<0.001	no flushing	
131 - staff lounge	160-131-1	0.003	<0.001	no flushing	
127 - toddler room	160-127-1	0.001	<0.001	no flushing	
	160-127-2	0.001	<0.001	no flushing	
South Carleton H.S.	Filling Station	214-FS2-B	0.016	0.002	daily
Stittsville P.S.	102-kindergarten	140-102-1	0.004	0.001	weekly
Westwind	107 servery	150-107-1	<0.001	<0.001	no flushing

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.