

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
Agincourt	114-kindergarten	076-114-1	0.006	0.002	daily
Briargreen	135	006-135-2	<0.001	<0.001	daily
Broadview	125-kindergarten	080-125-1	<0.001	<0.001	no flushing
Churchill	115-kindergarten	086-108-1	<0.001	<0.001	no flushing
Confederation	Filling Station	205-FS2-B	0.004	0.002	daily
D.Roy Kennedy	142-kindergarten	090-102-1	0.006	0.001	daily
Elizabeth Wynwood	108 - foods room	216-108-1	<0.001	<0.001	no flushing
		216-108-2	<0.001	<0.001	no flushing
		216-108-3	0.001	<0.001	no flushing
Knoxdale (029)	135-kindergarten	029-K114-1	0.002	0.001	daily
Greenbank (023)	Filling Station	023-FS1-B	0.001	<0.001	daily
Manordale	130-kindergarten	034-JK/SK19-1	<0.001	<0.001	weekly
Meadowlands	116-kindergarten	036-116-2	0.001	<0.001	weekly
Merivale High School	153A - custodial lunchroom	210-153A-1	0.003	0.001	daily
Nepean H.S.	Filling Station	234-FS1-B	<0.001	<0.001	daily
Pinecrest	117	115-20-1	<0.001	<0.001	daily
Regina Street	108-kitchen	123-36-1	0.001	<0.001	daily
Severn Ave	121-kindergarten	128-121-1	<0.001	<0.001	no flushing
Sir Guy Carleton	Drinking Fountain	211-F8	0.863	0.029	daily
			- fountain removed -		
Sir Robert Borden H.S.	Drinking Fountain	213-F11	0.001	<0.001	daily
	Drinking Fountain	213-F12	0.002	<0.001	daily
	Drinking Fountain	213-F13	<0.001	<0.001	daily
Sir Winston Churchill	103-staffroom	052-103-1	0.002	<0.001	weekly
Woodroffe H.S.	Filling Station	237-FS10-A	<0.001	<0.001	no flushing
		237-FS10-B	<0.001	<0.001	no flushing
Woodroffe Avenue P.S	128-kindergarten	133-128-1	0.009	0.002	daily
Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)					
Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.					
Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.					