

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
<b>Avalon</b>	Filling Station	143-FS1-B	<0.001	<0.001	no flushing
<b>Cairine Wilson</b>	Filling Station	203-FS1-B	<0.001	<0.001	no flushing
<b>Carson Grove</b>	Filling Station	008-FS1-B	0.002	0.001	daily
<b>Colonel By S.S.</b>	139F-kitchen	204-139F-1	0.004	0.002	daily
	232 - breakfast program	204-232-1	0.022	0.003	daily
<b>Convent Glen</b>	Filling Station	011-FS1-B	0.008	0.008	daily
<b>Dunning-Foubert</b>	137-kindergarten	058-8-1	0.003	0.001	daily
<b>Emily Carr</b>	Filling Station	013-FS2-B	<0.001	<0.001	weekly
<b>Fallingbrook</b>	117-kindergarten	065-137-1	0.041	0.006	daily
<b>Forest Valley</b>	106-kindergarten	067-23-1	<0.001	<0.001	weekly
<b>Glen Ogilvie</b>	103-kindergarten	019-111-1	0.005	0.001	daily
<b>Gloucester H.S.</b>	1116 - Custodial	208-155-1	0.001	0.001	daily
<b>Henry Larsen</b>	158-kindergarten	062-A1-2	0.003	0.001	daily
<b>Henry Munro</b>	Filling Station	025-FS5-A	0.001	<0.001	daily
		025-FS5-B	0.001	<0.001	daily
<b>Heritage</b>	138-FS1-B	138-FS1-B	<0.001	<0.001	no flushing
<b>Le Phare</b>	101-kindergarten	032-100-1	<0.001	<0.001	no flushing
<b>MacSkimming Farm</b>	Pioneer Village	Mac-Pioneer-2	<0.001	<0.001	weekly
	Pioneer/Galloway	Mac-Galloway -1	0.010	0.001	weekly
	Trails End	Mac-Trails-3	0.001	<0.001	weekly
	Agriculture	Mac-Agriculture-1	0.002	0.001	weekly
<b>Maple Ridge</b>	Filling Station	060-FS2-B	<0.001	<0.001	no flushing
<b>Norman Johnston</b>	126-Custodial office	220-custodial-1	0.003	0.001	daily
<b>Orleans Wood</b>	137-kindergarten	059-137-1	0.005	0.002	daily
	138-kindergarten	059-138-1	0.002	0.002	daily
<b>Ottawa Tech.</b>	105 - staffroom	233-105-1	0.020	0.016	daily
				resample 1 = 0.161	
				resample 2 = 0.005	
				resample 3 = 0.006	
<b>Robert Hopkins</b>	136-kindergarten	049-A2-1	0.004	0.001	daily
<b>Sir Wilfred Laurier S.S.</b>	Filling Station	218-FS2-B	<0.001	<0.001	weekly
<b>SummerSide</b>	Filling Station	151-FS1-B	<0.001	<0.001	no flushing
<b>Terry Fox</b>	100G-Health Room	024-Health-1	0.012	0.002	daily
<b>Trillium</b>	Filling Station	072-FS1-B	<0.001	<0.001	no flushing

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.