

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
A.Y. Jackson	105 - staff lounge	201-105-1	0.018	1.48	daily
				resample 1 = 0.109	
				resample 2 = 0.008	
				resample 3 = 0.002	
Bayshore Public School	115 - kindergarten	002-12-1	<0.001	<0.001	daily
Bell High School	Filling Station	202-FS9-B	0.008	0.003	daily
Bells Corners PS	111-staffroom	003-111-1	<0.001	<0.001	daily
Bill Mason	Kitchen	BillMason -1	0.001	<0.001	weekly
Bridlewood	112-kindergarten	064-112-2	0.006	0.001	daily
Castlefrank	Filling Station	066-FS4-B	<0.001	<0.001	daily
Crystal Bay	149	200-27-1	0.002	0.002	daily
Earl of March H.S.	Filling Station	206-FS11-B	<0.001	<0.001	daily
Frederick Banting	139- kitchen - off gym	221-Kitchen-1	0.024	0.006	daily
Glen Cairn	Filling Station	018-FS4-B	0.002	<0.001	daily
Huntley Centennial	150-kindergarten	026-38-1	0.003	0.002	weekly
Jack Donohue	118-kindergarten	136-106-1	<0.001	<0.001	no flushing
John Young	141-sk	027-141-1	0.004	0.002	daily
Kanata Highlands	124-kindergarten	152-124-1	<0.001	<0.001	weekly
Katimavik	Filling Station	057-FS3-B	0.001	<0.001	daily
Lakeview	127-kindergarten	030-127-1	0.003	<0.001	daily
Roch Carrier	Filling Station	139-FS2-B	<0.001	<0.001	no flushing
Roland Michener	143-kindergarten	050-135-1	0.018	0.015	daily
				resample 1 = 0.006	
				resample 2 = 0.004	
South March	147 servery	146-147-1	0.002	<0.001	weekly
Stephen Leacock	Filling Station	053-FS3-B	<0.001	<0.001	daily
Stonecrest	123-kindergarten	074-102-1	<0.001	0.008	weekly
W.E. Johnston	141 staffroom	056-141-1	0.001	0.001	daily
W.O. Mitchell	134-staffroom	068-134-1	<0.001	<0.001	daily
West Carleton SS	255 - staffroom	219-255-1	0.001	<0.001	daily
	150 - staff lounge	219-150-1	0.006	0.004	daily
	119 - nutrition	219-119-1	0.067	0.011	daily
			resample 1 = 0.010		
				resample 2 = 0.007	

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.