

| School Name                      | Room Number              | Sample ID<br><small>(school # - room # - sink #)</small> | Results  |   | Flushing Requirement |
|----------------------------------|--------------------------|--|----------|---|----------------------|
|                                  |                          |  | Standing | Flushed   |                      |
| A. Lorne Cassidy                 | Filling Station          | 71-F53-B   | <0.001   | <0.001  | daily                |
| Adrienne Clarkson                | 104-kindergarten         | 051-104-2  | <0.001   | <0.001  | no flushing          |
| Barrhaven                        | Filling Station          | 001-F54-B  | 0.002    | <0.001  | daily                |
| Berrigan                         | 151 - Staffroom          | 137-Staff-1  | <0.001   | <0.001  | no flushing          |
| Castor Valley                    | 144-kindergarten         | 063-1-1  | <0.001   | <0.001  | weekly               |
| Cedarview                        | Filling Station          | 073-F53-B  | <0.001   | <0.001  | no flushing          |
| Chapman Mills                    | Filling Station          | 147-F51-B  | <0.001   | <0.001  | no flushing          |
| D. A. Moodie                     | Filling Station          | 012-F52-A  | <0.001   | <0.001  | daily                |
| Farley Mowat                     | Filling Station          | 142-F52-B  | <0.001   | <0.001  | no flushing          |
| Goulbourn                        | Filling Station          | 020-F51-B  | 0.004    | 0.001   | daily                |
| Greely                           | 117 - staffroom          | 022-117-1  | 0.003    | 0.002   | weekly               |
| Half Moon Bay                    | Filling Station          | 153-F53-B  | <0.001   | <0.001  | no flushing          |
| Jockvale                         | 113-kindergarten         | 061-7-1  | 0.032    | 0.013<br>resample 1 = 0.007<br>resample 2 = 0.008 | daily                |
| John McCrae S.S.                 | Filling Station          | 238-F55-B  | <0.001   | <0.001  | weekly               |
| Kars on the Rideau               | Filling Station          | 047-F51-A  | 0.001    | <0.001  | weekly               |
| Longfields-Davidson Heights S.S. | Filling Station          | 239-F510-B   | <0.001   | <0.001  | weekly               |
| Manotick                         | 107-staffroom            | 035-6-1  | 0.002    | <0.001  | daily                |
| Maplewood S.S.                   | Drinking Fountain        | 242-F3   | <0.001   | <0.001  | no flushing          |
|                                  | Drinking Fountain        | 242-F4   | <0.001   | <0.001  | no flushing          |
|                                  | Drinking Fountain        | 242-F5   | <0.001   | <0.001  | no flushing          |
|                                  | Drinking Fountain        | 242-F6   | <0.001   | <0.001  | no flushing          |
|                                  | Drinking Fountain        | 242-F7   | 0.005    | <0.001  | weekly               |
|                                  | Drinking Fountain        | 242-F53-A  | 0.001    | <0.001  | no flushing          |
|                                  | Filling Station          | 242-F53-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 242-F54-A  | 0.002    | 0.002   | weekly               |
|                                  | Filling Station          | 242-F54-B  | 0.002    | <0.001  | weekly               |
|                                  | Filling Station          | 242-F55-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 242-F55-B  | 0.001    | <0.001  | no flushing          |
|                                  | Filling Station          | 242-F56-A  | 0.002    | <0.001  | weekly               |
|                                  | Filling Station          | 242-F56-B  | 0.002    | 0.003   | weekly               |
|                                  | Filling Station          | 242-F57-A  | 0.002    | 0.002   | weekly               |
|                                  | Filling Station          | 242-F57-B  | <0.001   | <0.001  | weekly               |
| 111-Staff Lounge                 | 242-111-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 221 - teachers resource          | 242-221-1                | 0.002  | <0.001   | weekly  |                      |
| 314 - teachers resource          | 242-314-1                | 0.001  | <0.001   | no flushing                                       |                      |
| Mary Honeywell                   | 107-kindergarten         | 069-107-1  | 0.001    | <0.001  | weekly               |
| Metcalfe                         | 122-kindergarten         | 039-114-2  | <0.001   | <0.001  | weekly               |
| Mino Mikan                       | Filling Station          | 162-F51-A  | 0.002    | <0.001  | weekly               |
|                                  | Filling Station          | 162-F51-B  | 0.003    | <0.001  | weekly               |
|                                  | Filling Station          | 162-F52-A  | 0.001    | <0.001  | no flushing          |
|                                  | Filling Station          | 162-F52-B  | 0.001    | <0.001  | no flushing          |
|                                  | Filling Station          | 162-F54-A  | 0.003    | <0.001  | weekly               |
|                                  | Filling Station          | 162-F54-B  | 0.001    | <0.001  | weekly               |
|                                  | Filling Station          | 162-F55-A  | 0.001    | <0.001  | no flushing          |
|                                  | Filling Station          | 162-F55-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 162-F56-A  | <0.001   | <0.001  | weekly               |
|                                  | Filling Station          | 162-F56-B  | 0.003    | <0.001  | weekly               |
|                                  | Filling Station          | 162-F57-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 162-F57-B  | 0.001    | <0.001  | no flushing          |
|                                  | Filling Station          | 162-F58-A  | 0.003    | <0.001  | weekly               |
|                                  | Filling Station          | 162-F58-B  | 0.004    | 0.001   | weekly               |
|                                  | 116                      | 162-116-1  | <0.001   | <0.001  | no flushing          |
|                                  | 117                      | 162-117-1  | <0.001   | <0.001  | no flushing          |
|                                  | 117                      | 162-117-2  | <0.001   | <0.001  | no flushing          |
|                                  | 118                      | 162-118-1  | <0.001   | <0.001  | no flushing          |
|                                  | 118                      | 162-118-2  | <0.001   | <0.001  | no flushing          |
|                                  | 119                      | 162-119-1  | 0.001    | <0.001  | weekly               |
| 119                              | 162-119-2                | 0.002  | <0.001   | weekly  |                      |
| 136                              | 162-136-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 136                              | 162-136-2                | <0.001   | <0.001   | no flushing                                       |                      |
| 137                              | 162-137-1                | <0.001   | <0.001   | daily   |                      |
| 137                              | 162-137-2                | 0.015  | <0.001   | daily   |                      |
| 138                              | 162-138-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 138                              | 162-138-2                | <0.001   | <0.001   | no flushing                                       |                      |
| North Gower                      | 103-kitchen              | 041-103-1  | 0.003    | 0.002   | daily                |
| Osgoode Township H.S.            | 111c - Cafeteria Kitchen | 212-cafeteria kitchen-1                                  | 0.001    | 0.001   | daily                |
| Osgoode P.S.                     | 112-kindergarten         | 042-112-1  | 0.001    | <0.001  | weekly               |
| Richmond                         | 104-kitchen              | 046-104-1  | 0.006    | 0.003   | daily                |
| Shingwákon's P.S.                | Filling Station          | 160-F56-B  | <0.001   | <0.001  | no flushing          |
| South Carleton H.S.              | Drinking Fountain        | 214-F11  | 0.002    | 0.002   | daily                |
| South Carleton H.S.              | 101B - Kitchen           | 214-kitchen-4  | 0.006    | 0.002   | daily                |
| Stittsville P.S.                 | 111-kindergarten         | 140-111-1  | 0.002    | <0.001  | weekly               |
| Wazoon                           | Filling Station          | 159-F51-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F51-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F52-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F52-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F53-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F53-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F54-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F54-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F55-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F55-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F56-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F56-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F57-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F57-B  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F58-A  | <0.001   | <0.001  | no flushing          |
|                                  | Filling Station          | 159-F58-B  | <0.001   | <0.001  | no flushing          |
|                                  | Servery                  | 159-135-2  | <0.001   | <0.001  | no flushing          |
|                                  | staffroom                | 159-101-1  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 116         | 159-116-1  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 116         | 159-116-2  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 117         | 159-117-1  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 117         | 159-117-2  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 118         | 159-118-1  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 118         | 159-118-2  | <0.001   | <0.001  | no flushing          |
|                                  | kindergarten 119         | 159-119-1  | <0.001   | <0.001  | no flushing          |
| kindergarten 119                 | 159-119-2                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 136                 | 159-136-1                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 136                 | 159-136-2                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 137                 | 159-137-1                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 137                 | 159-137-2                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 138                 | 159-138-1                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 138                 | 159-138-2                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 139                 | 159-139-1                | <0.001   | <0.001   | no flushing                                       |                      |
| kindergarten 139                 | 159-139-2                | <0.001   | <0.001   | no flushing                                       |                      |
| 131 Staff lounge                 | 159-131-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 124 - Kitchen                    | 159-124-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 124 - Kitchen                    | 159-124-2                | 0.001  | <0.001   | no flushing                                       |                      |
| 125 - pre school                 | 159-125-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 125 - pre school                 | 159-125-2                | <0.001   | <0.001   | no flushing                                       |                      |
| 127 - toddler & kinder           | 159-127-1                | <0.001   | <0.001   | no flushing                                       |                      |
| 127 - toddler & kinder           | 159-127-2                | <0.001   | <0.001   | no flushing                                       |                      |
| Westwind                         | Filling Station          | 150-F51-A  | <0.001   | <0.001  | no flushing          |

Safe Drinking Water Act 2002. Ontario Regulation 240/07 indicates the maximum allowable concentration of lead in drinking water is 0.01mg/L (milligramme/litre).

0.015 mg/L is the maximum allowable concentration of lead in drinking water in Ontario (milligramme/litre).

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.