

| School Name | Room Number | Sample ID (school # - room # - sink #) | Results | | Flushing Requirement |
|---------------------------------|--------------------------|---|----------|---------------------|----------------------|
| | | | Standing | Flushed | |
| Avalon | 114 kitchen-off gym | 143-114-2 | 0.002 | <0.001 | daily |
| Cairine Wilson | 153 - kitchen | 203-103-1 | <0.001 | <0.001 | no flushing |
| Carson Grove | 107-kindergarten | 008-17-1 | 0.013 | 0.001 | daily |
| Colonel By S.S. | Drinking Fountain | 204-F3 | 0.023 | 0.009 | daily |
| Convent Glen | 132 | 011-132-2 | 0.005 | 0.003 | daily |
| Dunning-Foubert | 138-kindergarten | 058-9-1 | 0.007 | 0.001 | daily |
| Emily Carr | 106 - Drinking Fountain | 013-F1 | 0.018 | 0.007 | daily |
| | 201B - main office | 013-201B-1 | 0.009 | 0.002 | weekly |
| Fallingbrook | 116 - JK Kindergarten | 065-JKKINDER-1 | 0.225 | 0.131 | daily |
| | | | | resample 1 = 0.018 | |
| | | | | resample 2 = 0.300 | |
| | | | | resample 3 = 0.071 | |
| | | | | resample 4 = 0.005 | |
| | | | | resample 5 = 0.017 | |
| | | | | resample 6 = 0.005 | |
| | | | | resample 7 = 0.014 | |
| | | | | resample 8 = 0.008 | |
| resample 9 = 0.002 | | | | | |
| Forest Valley | 122 - Kitchen off gym | 067-Kitchen-1 | <0.001 | <0.001 | weekly |
| Glen Ogilvie | 103-kindergarten | 019-111-2 | 0.045 | 0.020 | weekly |
| | | | | resample 1= 0.002 | |
| | | | | resample 2 = 0.002 | |
| Gloucester H.S. | 1058- family studies | 208-1058-3 | 0.016 | 0.003 | daily |
| Henry Larsen | 159-kindergarten | 062-A3-2 | 0.007 | 0.002 | daily |
| Henry Munro | 133 - kitchen | 025-133-2 | 0.014 | 0.003 | daily |
| Heritage | 100E - health room | 138-100E-1 | 0.003 | 0.001 | weekly |
| Le Phare | 136-kindergarten | 032-1-1 | 0.002 | <0.001 | weekly |
| MacSkimming Farm | Pioneer Village | Mac-Pioneerkitchen-1 | <0.001 | <0.001 | weekly |
| | Pioneer/Galloway | Mac-Galloway -1 | 0.001 | 0.006 | weekly |
| | Trails End | Mac-Trailskitchen-1 | <0.001 | <0.001 | weekly |
| | Agriculture | Mac-Agriculture-1 | 0.001 | <0.001 | weekly |
| Maple Ridge | 113-kindergarten | 060-116-2 | <0.001 | <0.001 | no flushing |
| Norman Johnston | Filling Station | 220-FS2-B | <0.001 | <0.001 | daily |
| Orleans Wood | 121D - kitchen | 121D - kitchen | 0.200 | 0.078 | daily |
| | | | | resample 1 = 0.061 | |
| | | | | resample 2 = 0.047 | |
| | | | | resample 3 = 0.018 | |
| | | | | reasample 4 = 0.003 | |
| | | | | resample 5 = 0.034 | |
| | | | | resample 6 = 0.018 | |
| | | | | resample 7 = 0.002 | |
| resample 8 = 0.002 | | | | | |
| Ottawa Tech. | 102 - Food services | 233-102-5 | 0.041 | 0.005 | daily |
| Robert Hopkins | 135A - kindergarten | 049-A1-1 | 0.007 | 0.340 | daily |
| | | | | resample 1 = 0.017 | |
| | | | | resample 2 = 0.139 | |
| resample 3 = 0.002 | | | | | |
| Sir Wilfred Laurier S.S. | 155 - kitchen | 218-155-3 | 0.001 | <0.001 | weekly |
| SummerSide | 129-kindergarten | 151-129-2 | <0.001 | <0.001 | no flushing |
| Terry Fox | 133 - Servery - off gym | 024-Servery-1 | 0.016 | 1.97 | daily |
| | | | | resample 1 = 0.002 | |
| resample 2 = 0.002 | | | | | |
| Trillium | 120A - Kitchen - off gym | 072-Kitchen-2 | 0.004 | 0.002 | weekly |

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.