

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
Alta Vista	154 -main office	077-154-1	0.002	<0.001	daily
Arch Street	203	078-203-1	0.011	2.00 resample 1 = 0.004 resample 2 = 0.002	daily
Bayview	115-kindergarten	121-115-2	<0.001	<0.001	daily
Blossom Park	126	005-126-1	0.016	0.005	daily
Brookfield HS	203 - family studies	228-203-1	0.008	0.004	daily
	170- small kitchen	228-170-1	<0.001	<0.001	daily
	172 - kitchenette	228-172-1	<0.001	<0.001	daily
	165	228-165-1	0.018	0.002	daily
		228-165-2	0.025	0.002	daily
	164	228-164-1	0.017	0.005	daily
		228-164-2	0.054	0.005	daily
164a	228-164a-1	0.008	0.004	daily	
Canterbury H.S.	B039a - Cafeteria Kitchen	229-Kitchen-4	0.105	<0.001	daily
Carleton Heights	115-kindergarten	082-115-1	0.007	0.005	daily
Charles Hulse	126 - main office	084-118-1	0.013	0.004	daily
Clifford Bowey	115	087-115-1	0.009	0.014 resample 1 = 0.013 resample 2 = 0.005 resample 3 = 0.005	daily
Dunlop	150 -kindergarten	092-39-2	0.006	0.002	daily
Featherston Drive	121B - servery	095-121B-2	0.012	0.005	daily
	Filling Station	095-FS5-A	0.004	0.031	daily
				resample 1 = 0.001 resample 2 = 0.001	
Fielding Drive	104 - kitchen off gym	096-104-1	0.019	0.004	daily
General Vanier	108 - kindergarten	099-5-1	0.004	0.001	weekly
Hawthorne	Filling Station	104-FS1-B	0.001	<0.001	daily
Hillcrest H.S.	B002 - custodial lunch room	231-B002-1	0.044	0.012 resample 1 = 0.001 resample 2 = 0.001	daily
Pleasant Park	126-kindergarten	116-126-1	0.013	0.032 resample 1 = <0.001 resample 2 = <0.001	daily
Ridgemont H.S.	101A - staff kitchen	236-101A-1	0.004	0.002	daily
Riverview	120 - Staff Room	124-Staff-1	0.070	0.012 resample 1 = 0.017 resample 2 = 0.001 resample 3 = 0.008	daily
Robert Bateman	107-child care	125-107-1	0.055	0.002	daily
Roberta Bondar	Filling Station	126-FS3-B	<0.001	<0.001	weekly
Sawmill Creek	123-kindergarten	075-123-1	0.008	0.003	daily
Steve MacLean	111-kindergarten	141-111-1	<0.001	<0.001	no flushing
Vimy Ridge	Filling Station	148-FS2-A	<0.001	<0.001	no flushing
Vincent Massey	124-kindergarten	129-126-3	0.114	0.039 resample 1 = 0.021 resample 2 = 0.004 resample 3 = 0.027 resample 4 = 0.005 resample 5 = 0.004	daily
	211	129-211-1	0.046	0.003	daily

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.