

| School Name          | Room Number                 | Sample ID<br>(school # - room # - sink #) | Results  |   | Flushing Requirement |
|----------------------|-----------------------------|---|----------|---|----------------------|
|                      |                             |   | Standing | Flushed   |                      |
| Adult H.S.           | 268b - kitchen              | 227-218-kitchen-1                         | 0.002    | <0.001  | daily                |
|                      | Filling Station             | 227-FS11-A                                | 0.011    | 0.003   | daily                |
|                      |                             | 227-FS11-B                                | 0.007    | 0.003   | daily                |
| Albert Street Admin. | Filling Station             | 364-FS2-B                                 | 0.001    | <0.001  | daily                |
| Cambridge Street     | 116-kindergarten            | 081-5-1                                   | 0.008    | 0.013<br>resample 1 = 0.043<br>resample 2 = 0.027<br>resample 3 = 0.004 | daily                |
|                      | 117-kindergarten            | 081-4-1                                   | 0.066    | 0.005   | daily                |
| Centennial           | 135-kindergarten            | 083-15-2                                  | 0.001    | 0.001   | daily                |
| Connaught            | 127- kitchen                | 088-156-2                                 | 0.002    | <0.001  | daily                |
| Devonshire           | B104-kindergarten           | 091-B104-2                                | <0.001   | <0.001  | weekly               |
| Elgin Street         | 114-kindergarten            | 093-114-1                                 | 0.016    | 0.007   | daily                |
| Elmdale              | Kindergarten 104            | 094-104-1                                 | <0.001   | <0.001  | no flushing          |
| First Avenue         | 115                         | 097-105-1                                 | 0.019    | 0.008   | daily                |
|                      | 117-kindergarten            | 097-101-1                                 | 0.012    | 0.002   | daily                |
| Fisher Park          | 227a - Kitchen              | 098-Kitchen-1                             | 0.005    | 0.001   | daily                |
| Glashan              | B011 kitchen                | 102-B011-3                                | 0.004    | <0.001  | daily                |
|                      | Drinking Fountain           | 102-F1                                    | 0.008    | 0.004   | daily                |
| Glebe Collegiate     | 101 - servery               | 230-101-1                                 | 0.011    | 0.003   | daily                |
|                      | 343A - kitchen              | 230-343A-1                                | 0.042    | 0.006   | daily                |
| Hilson Avenue        | Filling Station             | 105-FS2-A                                 | 0.001    | <0.001  | daily                |
| Hopewell Avenue      | 204-kindergarten            | 106-207-1                                 | <0.001   | <0.001  | no flushing          |
| Lady Evelyn          | 101A                        | 135-101A-1                                | <0.001   | <0.001  | daily                |
| Lisgar Collegiate    | NB004A - off kitchen caf.   | 226-100A-1                                | 0.013    | 0.006   | daily                |
|                      | NB004B - kitchen            | 226-100C-2                                | 0.043    | 0.003   | daily                |
| Manor Park           | 211B - Library Whisper room | 110-35-1                                  | 0.116    | 0.023<br>resample 1 = 0.025<br>resample 2 = 0.013<br>resample 3 = 0.009 | daily                |
| Mutchmor             | Filling Station             | 113-FS5-B                                 | 0.017    | 0.031<br>resample 1 = 0.005<br>resample 2 = 0.003                       | daily                |
| Queen Elizabeth      | 136                         | 118-18-1                                  | 0.010    | 0.002   | daily                |
| Queen Mary           | 201 - lunch room            | 119-16-1                                  | 0.008    | 0.054<br>resample 1 = 0.032<br>resample 2 = 0.006<br>resample 3 = 0.005 | daily                |
| Richard Pfaff        | 225 -New foods room         | 112-20-kit-1                              | 0.073    | 0.004   | daily                |
| Robert E Wilson      | 103-staffroom               | 122-103-1                                 | 0.007    | 0.001   | daily                |
| Rockcliffe Park      | 119 - kindergarten          | 127-32-1                                  | 0.006    | 0.038<br>resample 1 = 0.007<br>resample 2 = 0.010                       | daily                |
| Viscount Alexander   | 112                         | 130-1-1                                   | 0.013    | 0.063<br>resample 1 = 0.002<br>resample 2 = 0.002                       | daily                |
| W.E Gowling          | 149-kindergarten            | 131-149-1                                 | 0.207    | 0.031<br>resample 1 = 0.002<br>resample 2 = 0.002                       | daily                |
|                      | 151-kindergarten            | 131-151-1                                 | 0.068    | 0.007   | daily                |
|                      | 102                         | 131-102-1                                 | 0.048    | 0.008   | daily                |
| York Street          | B017 - kindergarten         | 134-8-1                                   | <0.001   | <0.001  | daily                |

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.